

No.86/FSR/CFO/MD/2013

Dated: 20-04-2022

To

Principal,
Kunil ILMU Academy,
Rahman Nagar, Natekal, Assaigoli Post,
Mangaluru - 574 199,
Dakshina Kannada District.

Sir,

Sub: Issue of Revised 'Fire safety recommendation' to Kunil ILMU Academy constructed at R.S.No. 110/2, Natekal, Assaigoli Post, Manjanady Village, Mangaluru Taluk, Dakshina Kannada District.

Ref: 1. No.86/Advice/CFO/MD/2013 Dated 23-01-2014.
2. Your letter dated 22-03-2022.

><><*>*<><<

In the reference, cited at (1) above, Fire safety recommendation to to Kunil ILMU Academy constructed at R.S.No. 110/2, Natekal, Assaigoli Post, Manjanady Taluk, Dakshina Kannada District was issued. Now the applicant requested to issue revised Fire safety recommendation in his letter cited at (2). Accordingly me on 13-04-2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01. Name and Address of the Applicant. : Principal,
Kunil ILMU Academy,
Rahman Nagar, Natekal, Assaigoli Post,
Mangaluru - 574 199,
Dakshina Kannada District.
02. Name and Address of the premises. : Kunil ILMU Academy,
Rahman Nagar, Natekal, Assaigoli Post,
Mangaluru - 574 199,
Dakshina Kannada District.
03. Name and address of the Building owner : Kunil Academy,
Rahman Nagar, Natekal, Assaigoli Post,
Mangaluru - 574 199,
Dakshina Kannada District.
04. Number of buildings : One

MANAGER
KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST, MANJANADY VILLAGE
MANGALORE - 574 199



Ms. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
Aff. No: 830533, School Code: 45460
Rahman Nagar, Natekal, Assaigoli Post
Manjanady Village, Mangalore - 574199
Dakshina Kannada. immanu@gmail.com
2444046

05. Number of floors : Ground floor, ground mezzanine & 3 upper floors.

06. Floor-wise details of occupancy:-

Ground floor : Lobby, c.o.o. room, chief accountant room, cash counter, Administrator room, stationary & uniform room, delivery room, chairman room, conference room, store room & services.

Ground mezzanine : C.o.o. office room, store room & services.

1st floor : 10 class rooms, staff room & vice principal room.

2nd floor : 10 class rooms, staff room & principal room.

3rd floor : 07 class rooms, computer lab, library, sports room & 2 nos staff room.

07. Height of the building : 14.00 mtrs.

08. Site area : 3.50 Acres

09. Built-up area of each floor:-

Ground floor : 650.55 Sq.mtrs.

1st floor. : 614.52 Sq.mtrs.

2nd floor : 614.52 Sq.mtrs.

3rd floor : 614.52 Sq.mtrs.

10. Total built-up area : 2,494.11 Sq.mtrs.

11. Surrounding properties:-

North(Front) : Vacant land & approach road.

South(Rear) : Residential houses

East(Side) : Plywood factory.

West(Side) : Vacant land & approach road.

12. Open space available around the building :-

Block-A

North(Front) : 20.00 mtrs.

South(Rear) : 30.00 mtrs.

East(Side) : 05.00 mtrs.

West(Side) : 30.00 mtrs.

Allowed setbacks (open space) should be maintained free from further construction.



Ms. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
 Aff. No: 830533, School Code: 45480
 Rahaman Nagar, Natekal, Assaigoli Post
 Marjanady Village, Mangalore - 574199
 Dakshina Kannada District
 Mob: 9744000079

B. On inspection of this School/College premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the Premises	The premises abuts 06.00 mtrs. wide located on the northern side and the road is hardened to carry the weight of 45,000 kgs.	No remarks.
02.	Number of entrances	Two.	Complied
03.	Number of staircase	No. of staircases : One. Width of staircases : 01.50 mtrs. Width of treads : 0.30 mtr. Height of risers : 0.16 mtr. No. of risers per flight : 10 Nos. Height of handrails : 0.85 mtr.	Complied
04.	Portable extinguishers	Provided 2 Nos. ABC extinguisher of 6 kgs. capacity	A. One water mist extinguisher of 9 ltrs capacity should kept near staircase landing. B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity should be provided near diesel generator. C. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room. D. One ABC type fire extinguisher of 06 kgs capacity should be located as to be available within 15 mtrs. radius.

[Signature]
MANAGER
KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST, MANJANADY
MANGALORE - 574 199



Ms. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
Aff. No: 830533, School Code: 45460
Rahman Nagar, Natekal, Assaigoli Post
Manjanady Village, Mangalore - 574 199
Oaksinna Kannada, firechneg@gmail.com
Mob: 9746305070

(01)	(02)	(03)	(04)
05.	Hose reel hose system	Provided one Hose reel hose of 19 mm size and of 30 mtrs. length to reach the farthest point of each floor near staircase landing with a shut off branch of 5 mm size. The hose reel hose connected at each landing.	Complied
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Hose reel Hose System has been connected to an booster pump of 450 LPM.	Complied Further the system should be connected to an alternative source of power supply.
07	Diesel generator	Provided one generator of 82 KVA capacity.	Diesel generator should be provided to supply alternative power supply.
08.	Terrace tank	Not provided	The system should be connected to an over head tank of 5,000 ltrs capacity. (The water tank should be kept exclusively fire fight purpose) Note: If the existing building is not capable of sustaining the weight of 5,000 ltrs tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS Column structure. If there is no option to provide even the above mentioned overhead tank provision shall be made to provide underground water tank of same capacity with submersible pump of 5-7 HP capacity. Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
09	Escape routes	Not marked	

MS. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
 Aff. No: 830533, School Code: 45469
 Rahaman Nagar, Natekal, Assaigoli Post
 Manjanady Village, Mangalore - 574199
 Dakshina Kannada, fmkunil@gmail.com
 Mob: 9746805070



KUNIL ILMU ACADEMY
MANJANADY VILLAGE
RAHAMAN NAGAR, NATEKAL
ASSAIGOLI POST, MANGALORE - 574 199

(01)	(02)	(03)	(04)
10.	Fire order (Fire safety plans)	Not displayed	A notice board Have been indicated the action should be taken by the employees in case of any emergency should be displayed in each building with the telephone number of Mangaluru Fire Station i.e. . 101, 112 & 2211085/2213192/2423333 and the telephone number of nearest ambulance service & Police station.
11.	No smoking board	Not displayed	COTPA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor.
12	Fire Siren	Not installed	A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
13	Nominate one Fire Nodal Officer	--	A fire nodal officer shall be nominated either from teaching or non teaching staff.
14.	Fire fighting training	Not imparted	At-least 40% of Teaching and non Teaching staff should be got trained in basic fire fighting at the Karnataka Fire and Emergency Services, Chief Fire officer's Office, Pandeshwara, Mangaluru - 575 001 or at the R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore/ Regional Fire Officer, Range level.

15. **Fire precautionary measures :-**

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.

KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST, KANNADY VILLAGE
MANGALORE - 574 199



Ms. PUSPAATHA
PRINCIPAL
KUNIL ILMU ACADEMY
Aff. No: 830533, School Code: 45460
Rahman Nagar, Natekal, Assaigoli Post
Kannady Village, Mangalore - 574199
Phone: 974499, Email: kishan@kunal.academy.com

- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing Revised '**Fire Safety Recommendation**' to Kunil ILMU Academy constructed at R.S.No. 110/2, Natekal, Assaigoli Post, Manjanady Village, Mangaluru Taluk, Dakshina Kannada District subject to condition and compliance of the above recommendations in column -4 of serial - B within 3 months and compliance to the undersigned. The applicant has remitted Rs.20,000-00 (Rupees twenty thousand only) vide challan No. 069472895 dated 20-04-2022 at SBI, Mangaluru being the Advise fees.

This **Fire Safety Recommendation** is valid for only one year from the date of issue and it is renewable.



Yours faithfully,

Chief Fire officer

Karnataka State Fire & Emergency Services
Mangaluru - 575 001


Copy to:-

- 1) The Block Education Officer, Managaluru North Range, Balmata, Mangaluru
- 2) Copy submitted to the Deputy Director (Fire Prevention), Karnataka Fire & Emergency Services, Bengaluru for information.

MANAGER
KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST, MANJANADY VILLAGE
MANGALORE - 574 199

Ms. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
Aff. No: 830533, School Code: 45469
Rahaman Nagar, Natekal, Assaigoli Post
Manjanady Village, Mangalore - 574199
Dakshina Kannada, fmkunil@gmail.com
Mob: 9744305613

Remitter's copy



Challan Validity ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ	District ಜಿಲ್ಲೆ	Department Name ಇಲಾಖಾ ಹೆಸರು	DDO Office ಡಿಡಿಒ ಕಛೇರಿ	
Challan expires On 25/04/2022	DAKSHINA KANNADA	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISION FIRE OFFICE, KARNATAKA FIRE EMERGENCY SERVICES, MANGALORE ZONE, MANGALORE	
Category ವರ್ಗ	Date ದಿನಾಂಕ	Challan Reference Number ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ	DDO Code ಡಿಡಿಒ ಕೋಡ್	
Government	19/4/2022	CR0422007000379978	140160	
Remitter Name ಸಂದಾಯದಾರನ ಹೆಸರು	Headmaster Kunil ILMU Academy Mangalore Tq		Mobile Number ಮೊಬೈಲ್ ಸಂಖ್ಯೆ	
Address ವಿಳಾಸ	Revised FSR for Kunil School Building at R.S.No.110/2, Natekal, Assaigoli Post, Manjanady Village, Mangalore Tq, D K District		E-Mail ಇ-ಮೇಲ್	
Purpose ಉದ್ದೇಶ	Head of Account ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ	Sub Purpose Name ಉಪ ಉದ್ದೇಶ ಹೆಸರು	Purpose Specific ID ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ	Amount ಮೊತ್ತ
OTHER ITEMS- FIRE DEPARTMENT	0070~60~109~0~02~000	12.FOR ISSUE OF ADVISE ON FIRE PREVENTION AND FIRE FIGHTING FOR NON HIGH RISE BUILDINGS.	NA	20000
		Grand Total ಒಟ್ಟು ಮೊತ್ತ		20000.00
Remittance Bank ಸಂದಾಯ ಮಾಡುವ ಬ್ಯಾಂಕ್	STATE BANK OF INDIA	Total Amount in Words ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ	Twenty Thousand	
Payment Status ಪಾವತಿ ಹಂತ	Payment Yet To Be Made At Agency Bank			

Payment Details
ಪಾವತಿ ವಿವರಗಳುPayment Mode
ಪಾವತಿ ವಿಧ

Cash

MANAGER
KUNIL ILMU ACADEMY
RAHMAN NATEKAL
ASSAIGOLI POST, MANJANADY VILLAGE
MANGALORE - 574 199

20 APR 2022

CASH RECEIPT AND TRANSFER/CLS

Ms. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY

Assaigoli Post, Natekal, School Code: 45460
Manjanady Village, Mangalore - 574199
Mangalore - 574199
Mangalore - 574199

KUNIL ILMU ACADEMY

Rahman Nagar, Natekal, Assaigoli Post,
Manjanady Village, Mangalore-574199
Ph:0824-2203444/5/6/7
E-mail: kunililmuacademy@gmail.com
web: www.kunilschool.com

25/04.2022

Date :

To

Chief Fire officer
Karnataka State fire & emergency services
Mangalore


Sub: Requesting you to issue fire compliance Certificate


Respected Sir,


We have installed the fire fighting equipments and system in our school building. We are requesting you to inspect our premises and issue the fire compliance certificate for the purpose of CBSE affiliation renewal.

Thanking you

Regards


PRINCIPAL
KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST,
MANGALORE - 574199




PRINCIPAL
KUNIL ILMU ACADEMY
RAHMAN NAGAR, NATEKAL
ASSAIGOLI POST, MANJANADY VILLAGE
MANGALORE - 574 199


MS. PUSHPALATHA
PRINCIPAL
KUNIL ILMU ACADEMY
Aff. No:830533, School Code: 45460
Rahman Nagar, Natekal, Assaigoli Post
Manjanady Village, Mangalore - 574199
Dakshina Kannada, Mangalore
Phone: 9746005070